

FACTORY LOCATED CURBS WITH A SINGLE PANEL RUNNING EAVE TO RIDGE: PANELS ARE TO BE DETAILED WITH AN ENDLAP AT THE UPSLOPE CURB LOCATION ONLY.

FIELD LOCATED CURBS WITH A SINGLE PANEL RUNNING EAVE TO RIDGE: PANELS AT CURB LOCATION MUST BE A MINIMUM OF 3" LONGER TO PERMIT FIELD CUTTING AND NOTCHING / REMOVAL OF FOAM AT UPSLOPE SPLICE LOCATION OF CURB.

FACTORY LOCATED CURBS ON MULTIPLE PANELS RUNNING EAVE TO RIDGE: PANELS MUST BE DETAILED FOR AN ENDLAP AT THE UPSLOPE CURB LOCATION.

FIELD LOCATED CURBS ON MULTIPLE PANELS RUNNING EAVE TO RIDGE: PANELS UPSLOPE OF CURB LOCATION MUST BE A MINIMUM OF 3" LONGER TO PERMIT FIELD CUTTING AND NOTCHING / REMOVAL OF FOAM AT UPSLOPE SPLICE LOCATION OF CURB.

ROOF ERECTION SEQUENCE IS LEFT TO RIGHT ON EACH PLANE

ENDLAP SUPPORT ANGLE UNDER CURB AREA ONLY.
L 2 X 4 X 16GA FIELD CUT TO LENGTH.

FIELD FABRICATE AND FIELD LOCATE ENDLAP.
REFERENCE STANDARD ENDLAP

