

ICC-ES Evaluation Report

ESR-2218

Reissued September 2019

Revised September 30, 2019

This report is subject to renewal September 2021.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

Section: 07 42 13—Metal Wall Panels

REPORT HOLDER:

METL-SPAN, A DIVISION OF NCI GROUP, INC.

EVALUATION SUBJECT:

METL-SPAN CF COMPOSITE FOAM WALL PANELS (M-S CF)

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2018, 2015, 2012, 2009 and 2006 *International Building Code*® (IBC)

Properties evaluated:

- Structural
- Fire resistance

1.2 Evaluation to the following green code(s) and/or standards:

- 2016 California Green Building Standards Code (CALGreen), Title 24, Part 11
- 2015, 2012 and 2008 ICC 700 *National Green Building Standard*™ (ICC 700-2015, ICC 700-2012 and ICC 700-2008)

Attributes verified:

See Section 3.1

2.0 USES

The Metl-Span CF composite foam plastic panels (M-S CF) described in this report are used as exterior and interior nonload-bearing wall panels of nonfire-resistance-rated, Type I, II, III, IV (noncombustible) or V building construction. For use as exterior wall panels where noncombustible construction is required, the panels' installation must conform to Section 4.3 of this report.

3.0 DESCRIPTION

3.1 General:

The M-S CF panels are factory-assembled, metal-faced, sandwich panels with a chemically bonded, continuously foamed-in-place foam plastic core. The panels recognized in this report have identical side joints and liner profiles. The difference between the panels is the exterior fascia skin profile. Three exterior fascia profiles are available:

Architectural Flat, Fluted, and Mesa. Panels have model numbers CF-30, CF-36, and CF-42, which correspond to standard 30-, 36- and 42-inch (762, 914 and 1067 mm) widths. The panels are available in thicknesses of 2, 2¹/₂, 3, 4, 5 and 6 inches (51, 64, 76, 102, 127, and 152 mm). Maximum panel length is 65 feet (19,812 mm). See Figure 1 for an illustration of the wall panel profiles.

The attributes of the composite foam plastic panels have been verified as conforming to the provisions of (i) CALGreen Sections A4.405.1.3 (prefinished materials) and A5.406.1.2 (reduced maintenance); (ii) ICC 700-2015 and ICC 700-2012 Sections 601.7, 11.601.7, and 12.1(A).601.7 (site-applied finishing materials); and (iii) ICC 700-2008 Section 601.7 (site-applied finishing materials). Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside the scope of this report. The code may provide supplemental information as guidance.

3.2 Materials:

3.2.1 Panel Core: The core of the wall panels is a polyurethane foam plastic as specified in the approved quality documentation. The cores have a 2.17 pcf nominal density, and have a flame-spread index of 25 or less and a smoke-developed index of 450 or less when tested in accordance with ASTM E84. The foam plastic is continuously foamed-in-place into the core of the panel during panel fabrication.

3.2.2 Panel Skins: Panel skins are identified as “fascia skin” and “liner skin.” “Fascia skin” is the panel skin material facing the exterior of the building, whereas “liner skin” is the panel skin material facing the interior of the building. The fascia and liner skins can have equal or different thicknesses. The three types of fascia skin profiles are denoted by a single character, as follows:

- A = “Architectural Flat” profile, for wall panels having a maximum width of 36 inches (914 mm).
- F = “Fluted” profile, for wall panels having a maximum width of 42 inches (1067 mm).
- M = “Mesa” profile, for wall panels having a maximum width of 42 inches (1067 mm).

For example, the product designation CF-42-FM-22/26 indicates a composite foam panel that has a 42-inch (1067 mm) panel cover width, a “Fluted” fascia profile and a “Mesa” liner profile, and No. 22 gage [0.030 inch (0.762 mm)] and No. 26 gage [0.019 inch (0.483 mm)] fascia and liner skin steel thicknesses, respectively.

Panel facing material is steel conforming to ASTM A653 SS (Structural Steel) Grade 33, with Class G 90 galvanization coating, or steel conforming to ASTM A792 SS Grade 33, with a Class AZ50 galvalume coating. Facing material thickness is No. 26 or No. 22 gage, with an uncoated metal thickness of 0.0190 or 0.0300 inch (0.483 or 0.762 mm), respectively. Finishes applied over the facing material must comply as a Class A finish in accordance with IBC Section 803.1.

3.2.3 Connections:

3.2.3.1 U-Clips: The U-clips are brackets that are used to fasten the wall panels to supporting framing. The U-Clips are galvanized or stainless steel, and measure 1 inch (25.4 mm) wide by 4 inches (102 mm) long by No. 14 gage [0.068 inch (1.727 mm)]. See Figures 2 and 3 for details of the U-clip and its application.

3.2.3.2 U-Clip Fasteners: Screws used to attach the panels to steel supports must be minimum No. 14, self-drilling or self-tapping screws, complying with SAE J78. The screws used with the panels must be sufficiently long to penetrate through the structural supporting member. The fastener connection to the supporting member must be designed to the satisfaction of the code official. The fasteners must be corrosion-resistant.

3.2.3.3 Expansion Fasteners: Fab-Lok® FAS/FAC 10-4, 10-8, and 10-12 fasteners are expansion fasteners used to attach the panels to steel supports. The fasteners have three different grip ranges: 0 to 1/4 inch (0 to 6.4 mm), 1/4 to 1/2 inch (6.4 to 12.7 mm), and 1/2 to 3/4 inch (12.7 to 19 mm), respectively. The fastener connection to the supporting member must be designed to the satisfaction of the code official. The fasteners must be corrosion-resistant.

3.2.4 Sealants: Butyl caulk is used for panel joints, and butyl sealant tape is used for trim. The caulk must conform to Federal Specification TT-C-1796A, Type I, Class A. Sealant tape must conform to Federal Specification TT-C-1796A, Type II, Class A. The caulk and tape must be applied to clean and dry surfaces at temperatures as recommended by the caulk and tape manufacturers.

3.2.5 Flashing: Flashing material must be corrosion-resistant steel having the same gage as the panel fascia skin.

4.0 DESIGN AND INSTALLATION

4.1 Design:

An analysis must be submitted to the code official showing that the panel system, including fasteners and structural framing members, provides a complete load path capable of transferring all loads and forces from their point of origin to load-resisting elements. Tables 1 through 12 of this report contain allowable, out-of-plane, transverse, uniform wind loads for the wall panels based on panel stiffness, panel strength (both bending and horizontal shear), and panel connection design. Table 13 lists allowable spans for interior partition panels resisting a 5 psf (24 N/m²) transverse design load specified in 2018 IBC Section 1607.15 (2015 and 2012 IBC Section 1607.14 and 2009 and 2006 IBC Section 1607.13). Allowable loads presented in the tables for panels having No. 26 gage skins can be used for panels with No. 24 gage steel skins.

4.2 Installation:

Each wall panel must be placed with the panel's longitudinal edge oriented in the vertical or horizontal direction. Individual panels may span one, two, three or more spans. The panels are erected from left to right or right to left, leading with the male edge. See Figure 2 for

typical panel layout. The panels must be fastened to structural steel supports by means of U-clip brackets and U-clip fasteners placed in the tongue-and-groove longitudinal side joint of the panels. The structural support members must provide a minimum bearing width of 2.5 inches (64 mm) to the panels. The structural support members and the connection of the panels to the structural support members must be designed to resist the applied forces.

At the end supports, the wall panel clip (U-clip) must be fastened with one fastener. At the intermediate panel supports, the wall panel clip must be fastened with two fasteners. U-Clip fasteners must be as described in Section 3.2.3.2 of this report.

The longitudinal side joints of the panels have a 1/4-inch (6.4 mm) bead of butyl sealant that is either factory- or field-applied into one or both of the grooves of the panels. During erection, the side joints of adjacent panels are interlocked such that there is continuous contact of both panels with the sealant. Erection proceeds along the wall elevation, with the installation of successive panels in accordance with the published Metl-Span installation guide. Expansion fasteners, as described in Section 3.2.3.3, must be used to attach the liner facing to framing supports as required by the approved structural design. The expansion fasteners must be field-installed in accordance with the installation instructions. See Figure 3 for panel joint details and Figures 2, 4 and 5 for attachment details.

Provided the sealants and application of the sealants are satisfactory to the code official, panels exposed to weather do not require a weather-resistive barrier in accordance with Section 1405 of the IBC when panels are installed with sealant as specified in this section (Section 4.2) and wall openings and penetrations are flashed. Flashing must be placed in accordance with 2018 IBC Section 1404.4 (2015 IBC Section 1405.4 or 2012, 2009 and 2006 IBC Section 1405.3) on both ends of the panels when installation is at the building's base, and at eaves, openings, and horizontal and vertical corners. The flashing is attached to the panels with self-tapping, self-drilling screws or pop rivets in accordance with the published Metl-Span installation guide.

4.3 Types I, II, III, and IV (Noncombustible) Construction:

Metl-Span CF panels having a 6-inch (152 mm) maximum thickness are permitted to be used in exterior, nonload-bearing, noncombustible, nonfire-resistance-rated, multistory wall construction. Panels must be installed with the panel length oriented vertically or horizontally and be attached to steel framing. Wall stud cavities at floor-to-wall joints must be blocked with 4 lb/ft³ (64 kg/m³) density mineral wool insulation. Wall openings must be protected by placing 4 lb/ft³ (64 kg/m³) mineral wool insulation strips around openings covered with steel having a minimum 0.019-inch (0.48 mm) base-metal thickness mechanically fastened to panels.

5.0 CONDITIONS OF USE

The Metl-Span CF Composite foam panels described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

5.1 Panels must be installed in accordance with this report and the manufacturer's published installation instructions, a copy of which must be available at the jobsite. In the event of a conflict between this report and the manufacturer's published installation instructions, the more restrictive governs.

- 5.2 Wall panels must be limited to nonload-bearing wall applications.
- 5.3 Remaining portions of the structure, other than Metl-Span wall panels, must be designed and constructed in accordance with the code.
- 5.4 Construction plans, calculations for actual loading conditions and calculations for the connection of the panel to the supporting member must be submitted to the code official for approval.
- 5.5 All construction documents specifying the panels described in this report must comply with the design limitations of this report. Drawings and design details demonstrating that the Metl-Span panels comply with this report must be submitted to the code official at the time of permit application. The drawings and design details must be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.6 The Metl-Span CF panels described in this report have been justified for installation without the thermal barrier required by IBC Section 2603.4.
- 5.7 The panels must be fabricated by Metl-Span, A Division of NCI Group, Inc., at their manufacturing plants located in Lewisville, Texas, Shelbyville, Indiana, Prince George, Virginia, North Las Vegas, Nevada, Mattoon, Illinois and Ontario, Canada, under a quality-control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with the ICC-ES Acceptance Criteria for Sandwich Panels (AC04), dated February 2012 (editorially revised May 2018).
- 6.2 Data in accordance with the ICC-ES Acceptance Criteria for Foam Plastic Insulation (AC12), dated June 2015 (editorially revised October 2017).
- 6.3 Reports of testing in accordance with NFPA 285 and NFPA 286.

7.0 IDENTIFICATION

- 7.1 Each panel is identified on the edge or on the face with the product name, insulation manufacturer name, and flame-spread and smoke-development ratings. The panel package is labeled with the evaluation report number (ESR-2218), panel thickness, panel width, fascia/liner profile, and fascia/liner facing steel thickness.
- 7.2 The report holder's contact information is the following:

METL-SPAN, A DIVISION OF NCI GROUP, INC.
1720 LAKEPOINTE DRIVE, SUITE 101
LEWISVILLE, TEXAS 75057
(972) 221-6656
www.metlspan.com
cwstorch@ncigroup.com

Table 1: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 2 inches
 Panel Width: 30 inches (CF-30) or 36 inches (CF-36)
 Fascia/Liner Profile: Mesa/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)							
		Panel Stiffness and Strength		Panel Connection Strength ³					
		L/180	Strength	Pattern 1		Pattern 2		Pattern 3	
				CF-30	CF-36	CF-30	CF-36	CF-30	CF-36
5	1	93.4	77.2	41.7	34.7	62.3	51.9	84.8	70.7
	2	100.2	68.7	47.5	39.6	71.1	59.2	89.0	74.1
	3	101.4	67.6	48.6	40.5	72.6	60.5	93.3	77.7
6	1	70.6	64.3	34.7	29.0	51.9	43.3	70.7	58.9
	2	79.0	56.1	40.7	33.9	60.8	50.7	72.7	60.6
	3	79.6	55.7	41.1	34.3	61.5	51.3	77.2	64.4
7	1	54.5	55.1	29.8	24.8	44.5	37.1	60.6	50.5
	2	63.9	47.4	35.6	29.7	53.0	44.2	61.3	51.1
	3	64.0	47.3	35.7	29.7	53.3	44.4	65.9	54.9
8	1	42.8	48.2	26.1	21.7	39.0	32.5	53.0	44.2
	2	52.7	40.9	31.4	26.1	45.8	38.2	53.0	44.2
	3	52.3	41.2	31.5	26.2	47.1	39.2	57.5	47.9
9	1	34.1	40.4	23.2	19.3	34.6	28.9	47.1	39.3
	2	44.0	36.0	27.6	23.0	40.3	33.6	46.7	38.9
	3	43.2	36.4	28.2	23.5	42.1	35.1	51.0	42.5
10	1	27.5	32.7	20.8	17.4	31.2	26.0	42.4	35.3
	2	37.2	32.2	24.7	20.6	36.0	30.0	41.7	34.7
	3	36.1	32.7	25.5	21.2	38.1	31.7	45.8	38.2
11	1	22.4	27.0	19.0	15.8	28.3	23.6	38.6	32.1
	2	31.8	29.1	22.3	18.6	32.5	27.1	37.6	31.4
	3	30.4	29.6	23.2	19.4	34.7	28.9	41.6	34.6
12	1	18.5	22.7	17.4	14.5	26.0	21.6	35.3	29.5
	2	27.3	26.5	20.3	16.9	29.7	24.7	34.3	28.6
	3	25.8	27.1	21.4	17.8	31.9	26.6	38.1	31.7

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 2: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 2 inches
 Panel Width: 30 inches (CF-30) or 36 inches (CF-36)
 Fascia/Liner Profile: Architectural/Mesa
 Fascia/Liner Steel Thickness: 22/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)							
		Panel Stiffness and Strength		Panel Connection Strength ³					
		L/180	Strength	Pattern 1		Pattern 2		Pattern 3	
				CF-30	CF-36	CF-30	CF-36	CF-30	CF-36
5	1	100.8	79.1	43.1	35.9	63.7	53.1	86.2	71.8
	2	106.1	71.4	48.3	40.2	71.4	59.5	91.9	76.6
	3	107.3	70.0	49.5	41.3	73.3	61.1	95.6	79.6
6	1	77.5	65.9	35.9	29.9	53.1	44.2	71.8	59.8
	2	84.2	58.3	41.3	34.4	61.0	50.9	75.1	62.6
	3	85.1	57.5	42.0	35.0	62.2	51.8	79.1	65.9
7	1	60.9	56.5	30.8	25.6	45.5	37.9	61.6	51.3
	2	68.6	49.2	36.2	30.1	53.5	44.6	63.3	52.7
	3	69.1	48.8	36.5	30.4	54.0	45.0	67.4	56.2
8	1	48.5	49.5	26.9	22.4	39.8	33.2	53.9	44.9
	2	57.1	42.5	32.2	26.9	47.4	39.5	54.6	45.5
	3	57.1	42.4	32.3	26.9	47.7	39.8	58.8	49.0
9	1	39.2	40.6	23.9	19.9	35.4	29.5	47.9	39.9
	2	48.1	37.3	28.8	24.0	41.6	34.7	48.0	40.0
	3	47.8	37.5	28.9	24.1	42.7	35.6	52.1	43.4
10	1	32.0	32.9	21.5	17.9	31.9	26.5	43.1	35.9
	2	41.0	33.3	25.7	21.4	37.2	31.0	42.9	35.7
	3	40.4	33.6	26.2	21.8	38.7	32.2	46.8	39.0
11	1	26.4	27.2	19.6	16.3	29.0	24.1	39.2	32.6
	2	35.3	30.1	23.2	19.3	33.5	27.9	38.7	32.2
	3	34.4	30.5	23.9	19.9	35.3	29.4	42.5	35.4
12	1	22.0	22.9	17.9	15.0	26.5	22.1	35.9	29.9
	2	30.6	27.4	21.1	17.6	30.6	25.5	35.3	29.4
	3	29.5	27.9	22.0	18.3	32.5	27.1	38.9	32.4

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 3: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 2 inches
 Panel Width: 42 inches (CF-42)
 Fascia/Liner Profile: Mesa/Mesa Or Flute/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)				
		Panel Stiffness and Strength		Panel Connection Strength ³		
		L/180	Strength	Pattern 1	Pattern 2	Pattern 3
5	1	92.1	75.9	29.6	44.3	60.4
	2	98.8	67.6	33.7	50.5	63.4
	3	99.9	66.5	34.5	51.6	66.4
6	1	69.7	63.3	24.7	37.0	50.3
	2	77.8	55.3	28.8	43.2	51.7
	3	78.5	54.8	29.2	43.7	55.0
7	1	53.9	54.2	21.1	31.7	43.1
	2	63.0	46.6	25.3	37.7	43.7
	3	63.1	46.5	25.3	37.9	46.9
8	1	42.4	43.2	18.5	27.7	37.7
	2	52.0	40.3	22.3	32.6	37.7
	3	51.6	40.5	22.3	33.5	40.9
9	1	33.8	34.2	16.4	24.6	33.6
	2	43.5	35.5	19.6	28.7	33.2
	3	42.7	35.8	20.0	29.9	36.3
10	1	27.3	27.7	14.8	22.2	30.2
	2	36.8	31.7	17.5	25.6	29.7
	3	35.7	32.1	18.1	27.1	32.6
11	1	22.2	22.9	13.5	20.2	27.5
	2	31.4	27.8	15.8	23.2	26.8
	3	30.1	29.1	16.5	24.7	29.6
12	1	18.3	19.2	12.3	18.5	25.2
	2	27.0	22.7	14.4	21.1	24.4
	3	25.6	25.8	15.2	22.7	27.1

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 4: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 2.5 inches
 Panel Width: 30 inches (CF-30) or 36 inches (CF-36)
 Fascia/Liner Profile: Mesa/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)							
		Panel Stiffness and Strength		Panel Connection Strength ³					
		L/180	Strength	Pattern 1		Pattern 2		Pattern 3	
				CF-30	CF-36	CF-30	CF-36	CF-30	CF-36
5	1	120.1	87.7	47.5	39.6	68.1	56.8	90.6	75.5
	2	125.9	79.4	53.1	44.2	76.1	63.4	97.9	81.6
	3	127.3	77.7	54.5	45.4	78.2	65.2	101.6	84.7
6	1	92.6	73.1	39.6	33.0	56.8	47.3	75.5	62.9
	2	100.1	64.8	45.4	37.8	65.1	54.2	79.9	66.6
	3	101.2	63.9	46.3	38.6	66.4	55.3	84.0	70.0
7	1	72.9	62.6	33.9	28.3	48.7	40.6	64.7	53.9
	2	81.7	54.6	39.8	33.1	57.0	47.5	67.4	56.1
	3	82.4	54.2	40.2	33.5	57.7	48.1	71.6	59.7
8	1	58.3	54.8	29.7	24.7	42.6	35.5	56.6	47.2
	2	68.0	47.2	35.4	29.5	50.8	42.4	58.1	48.5
	3	68.2	47.1	35.5	29.6	51.0	42.5	62.4	52.0
9	1	47.2	46.9	26.4	22.0	37.9	31.5	50.3	42.0
	2	57.4	41.5	31.8	26.5	44.7	37.3	51.1	42.6
	3	57.1	41.6	31.8	26.5	45.7	38.0	55.3	46.1
10	1	38.7	38.0	23.8	19.8	34.1	28.4	45.3	37.8
	2	49.1	37.0	28.4	23.7	39.9	33.2	45.6	38.0
	3	48.4	37.3	28.8	24.0	41.3	34.4	49.7	41.4
11	1	32.0	31.4	21.6	18.0	31.0	25.8	41.2	34.3
	2	42.3	33.4	25.6	21.4	36.0	30.0	41.1	34.3
	3	41.3	33.8	26.3	21.9	37.8	31.5	45.1	37.6
12	1	26.7	26.4	19.8	16.5	28.4	23.7	37.8	31.5
	2	36.7	30.4	23.4	19.5	32.8	27.3	37.5	31.2
	3	35.4	30.9	24.2	20.2	34.7	28.9	41.3	34.4

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 5: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 2.5 inches
 Panel Width: 30 inches (CF-30) or 36 inches (CF-36)
 Fascia/Liner Profile: Architectural/Mesa
 Fascia/Liner Steel Thickness: 22/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)							
		Panel Stiffness and Strength		Panel Connection Strength ³					
		L/180	Strength	Pattern 1		Pattern 2		Pattern 3	
				CF-30	CF-36	CF-30	CF-36	CF-30	CF-36
5	1	127.5	89.4	48.8	40.7	69.5	57.9	92.0	76.6
	2	131.8	82.0	53.7	44.8	76.4	63.7	100.9	84.1
	3	133.2	80.0	55.3	46.1	78.7	65.6	103.9	86.6
6	1	99.6	74.5	40.7	33.9	57.9	48.2	76.6	63.9
	2	105.4	67.0	45.9	38.2	65.2	54.4	82.4	68.7
	3	106.6	65.7	47.0	39.2	66.9	55.7	85.9	71.6
7	1	79.6	63.9	34.9	29.1	49.6	41.4	65.7	54.7
	2	86.6	56.4	40.2	33.5	57.2	47.6	69.4	57.9
	3	87.5	55.7	40.9	34.1	58.2	48.5	73.2	61.0
8	1	64.5	55.9	30.5	25.4	43.4	36.2	57.5	47.9
	2	72.6	48.7	35.8	29.9	51.0	42.5	59.9	49.9
	3	73.1	48.3	36.2	30.2	51.5	42.9	63.8	53.1
9	1	52.9	49.6	27.1	22.6	38.6	32.2	51.1	42.6
	2	61.7	42.8	32.4	27.0	46.1	38.4	52.6	43.8
	3	61.9	42.7	32.5	27.1	46.2	38.5	56.5	47.1
10	1	43.9	40.1	24.4	20.3	34.7	28.9	46.0	38.3
	2	53.1	38.1	29.5	24.6	41.1	34.2	46.9	39.1
	3	52.9	38.2	29.4	24.5	41.9	34.9	50.7	42.2
11	1	36.7	33.2	22.2	18.5	31.6	26.3	41.8	34.8
	2	46.1	34.4	26.6	22.2	37.1	30.9	42.3	35.2
	3	45.5	34.6	26.9	22.4	38.3	31.9	46.0	38.3
12	1	30.9	27.9	20.3	17.0	28.9	24.1	38.3	31.9
	2	40.3	31.3	24.2	20.2	33.7	28.1	38.5	32.1
	3	39.5	31.6	24.8	20.6	35.2	29.4	42.1	35.1

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 6: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 2.5 inches
 Panel Width: 42 inches (CF-42)
 Fascia/Liner Profile: Mesa/Mesa Or Flute/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)				
		Panel Stiffness and Strength		Panel Connection Strength ³		
		L/180	Strength	Pattern 1	Pattern 2	Pattern 3
5	1	118.9	86.6	33.8	48.5	64.6
	2	124.5	78.4	37.7	54.2	69.8
	3	125.9	76.7	38.7	55.7	72.4
6	1	91.7	72.1	28.2	40.4	53.8
	2	99.0	64.0	32.2	46.3	57.0
	3	100.1	63.1	32.9	47.2	59.9
7	1	72.3	61.8	24.1	34.7	46.1
	2	80.9	54.0	28.2	40.6	48.0
	3	81.5	53.5	28.6	41.0	51.1
8	1	57.9	54.1	21.1	30.3	40.4
	2	67.3	46.6	25.2	36.2	41.5
	3	67.5	46.5	25.3	36.3	44.5
9	1	46.9	44.7	18.8	27.0	35.9
	2	56.9	40.9	22.7	31.9	36.4
	3	56.6	41.1	22.6	32.5	39.4
10	1	38.5	36.2	16.9	24.3	32.3
	2	48.6	36.5	20.2	28.4	32.5
	3	48.0	36.8	20.5	29.4	35.4
11	1	31.8	29.9	15.4	22.1	29.4
	2	41.9	33.0	18.2	25.6	29.3
	3	41.0	33.4	18.7	26.9	32.1
12	1	26.6	25.1	14.1	20.2	26.9
	2	36.4	30.0	16.6	23.4	26.7
	3	35.2	30.5	17.2	24.7	29.4

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 7: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 3 inches
 Panel Width: 30 inches (CF-30) or 36 inches (CF-36)
 Fascia/Liner Profile: Mesa/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)							
		Panel Stiffness and Strength		Panel Connection Strength ³					
		L/180	Strength	Pattern 1		Pattern 2		Pattern 3	
				CF-30	CF-36	CF-30	CF-36	CF-30	CF-36
5	1	144.3	97.1	52.8	44.0	73.4	61.2	95.9	79.9
	2	149.2	89.1	58.0	48.3	80.7	67.2	105.4	87.8
	3	150.7	86.9	59.8	49.8	83.1	69.3	108.6	90.5
6	1	112.8	80.9	44.0	36.6	61.2	51.0	79.9	66.6
	2	119.3	72.8	49.5	41.3	68.9	57.4	86.6	72.2
	3	120.7	71.3	50.8	42.3	70.6	58.9	90.3	75.2
7	1	90.1	69.4	37.7	31.4	52.4	43.7	68.5	57.1
	2	98.1	61.3	43.4	36.1	60.3	50.3	73.0	60.8
	3	99.1	60.5	44.2	36.8	61.5	51.2	76.9	64.1
8	1	73.1	60.7	33.0	27.5	45.9	38.2	59.9	49.9
	2	82.2	52.9	38.7	32.2	53.8	44.9	62.9	52.5
	3	82.8	52.5	39.1	32.6	54.4	45.3	67.0	55.8
9	1	60.0	52.8	29.3	24.4	40.8	34.0	53.3	44.4
	2	69.9	46.4	35.0	29.1	48.6	40.5	55.3	46.1
	3	70.1	46.3	35.1	29.2	48.8	40.7	59.3	49.5
10	1	49.8	42.8	26.4	22.0	36.7	30.6	47.9	39.9
	2	60.1	41.4	31.9	26.6	43.5	36.2	49.3	41.0
	3	59.9	41.5	31.8	26.5	44.2	36.8	53.3	44.4
11	1	41.6	35.3	24.0	20.0	33.4	27.8	43.6	36.3
	2	52.2	37.3	28.7	24.0	39.2	32.7	44.4	37.0
	3	51.6	37.6	29.0	24.2	40.4	33.7	48.3	40.3
12	1	35.1	29.7	22.0	18.3	30.6	25.5	39.9	33.3
	2	45.7	34.0	26.2	21.8	35.7	29.7	40.4	33.7
	3	44.7	34.3	26.7	22.3	37.2	31.0	44.2	36.9

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 8: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 3 inches
 Panel Width: 30 inches (CF-30) or 36 inches (CF-36)
 Fascia/Liner Profile: Architectural/Mesa
 Fascia/Liner Steel Thickness: 22/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)							
		Panel Stiffness and Strength		Panel Connection Strength ³					
		L/180	Strength	Pattern 1		Pattern 2		Pattern 3	
				CF-30	CF-36	CF-30	CF-36	CF-30	CF-36
5	1	151.4	98.7	54.0	45.0	74.7	62.2	97.2	81.0
	2	154.9	91.6	58.6	48.8	80.9	67.4	105.3	87.7
	3	156.3	89.3	60.4	50.3	83.5	69.6	108.6	90.5
6	1	119.8	82.2	45.0	37.5	62.2	51.9	81.0	67.5
	2	124.6	74.9	49.9	41.6	69.0	57.5	89.1	74.3
	3	126.0	73.2	51.4	42.8	71.0	59.1	92.2	76.8
7	1	96.8	70.5	38.6	32.2	53.3	44.5	69.4	57.8
	2	103.0	63.1	43.7	36.4	60.4	50.3	75.1	62.6
	3	104.2	62.0	44.7	37.3	61.8	51.5	78.5	65.4
8	1	79.5	61.7	33.8	28.1	46.7	38.9	60.7	50.6
	2	86.8	54.4	39.0	32.5	53.8	44.9	64.7	54.0
	3	87.7	53.7	39.6	33.0	54.8	45.7	68.3	56.9
9	1	66.1	54.8	30.0	25.0	41.5	34.6	54.0	45.0
	2	74.2	47.8	35.2	29.4	48.7	40.6	56.8	47.4
	3	74.8	47.4	35.6	29.7	49.2	41.0	60.5	50.4
10	1	55.4	44.9	27.0	22.5	37.3	31.1	48.6	40.5
	2	64.2	42.5	32.2	26.8	44.5	37.1	50.6	42.2
	3	64.4	42.4	32.3	26.9	44.6	37.2	54.3	45.2
11	1	46.9	37.1	24.6	20.5	33.9	28.3	44.2	36.8
	2	56.1	38.3	29.6	24.7	40.3	33.6	45.6	38.0
	3	56.0	38.4	29.5	24.6	40.8	34.0	49.2	41.0
12	1	39.9	31.2	22.5	18.8	31.1	25.9	40.5	33.7
	2	49.4	34.8	27.1	22.6	36.7	30.6	41.5	34.5
	3	48.9	35.1	27.2	22.7	37.6	31.4	45.0	37.5

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 9: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 3 inches
 Panel Width: 42 inches (CF-42)
 Fascia/Liner Profile: Mesa/Mesa Or Flute/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)				
		Panel Stiffness and Strength		Panel Connection Strength ³		
		L/180	Strength	Pattern 1	Pattern 2	Pattern 3
5	1	143.1	96.0	37.5	52.3	68.3
	2	147.8	88.2	41.2	57.4	75.0
	3	149.3	86.0	42.5	59.2	77.3
6	1	112.0	80.0	31.3	43.6	57.0
	2	118.3	72.0	35.2	49.0	61.8
	3	119.7	70.6	36.1	50.3	64.3
7	1	89.6	68.6	26.8	37.3	48.8
	2	97.3	60.7	30.8	42.9	52.0
	3	98.3	59.8	31.4	43.7	54.8
8	1	72.7	60.0	23.5	32.7	42.7
	2	81.5	52.3	27.5	38.3	44.9
	3	82.2	51.9	27.8	38.7	47.7
9	1	59.8	52.4	20.9	29.0	38.0
	2	69.4	46.0	24.8	34.6	39.4
	3	69.6	45.9	24.9	34.7	42.3
10	1	49.6	42.4	18.8	26.1	34.2
	2	59.7	41.0	22.7	31.0	35.1
	3	59.5	41.1	22.6	31.5	38.0
11	1	41.5	35.1	17.1	23.8	31.1
	2	51.9	36.9	20.5	27.9	31.7
	3	51.3	37.2	20.7	28.8	34.4
12	1	35.0	29.5	15.6	21.8	28.5
	2	45.4	33.6	18.6	25.4	28.8
	3	44.5	34.0	19.0	26.5	31.5

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 10: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 4 inches
 Panel Width: 42 inches (CF-42)
 Fascia/Liner Profile: Mesa/Mesa Or Flute/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)				
		Panel Stiffness and Strength		Panel Connection Strength ³		
		L/180	Strength	Pattern 1	Pattern 2	Pattern 3
5	1	183.0	100.8	36.5	51.2	67.3
	2	186.1	94.5	39.1	54.9	67.0
	3	187.4	92.0	40.3	56.6	68.3
6	1	145.9	84.0	30.4	42.7	56.0
	2	150.3	77.3	32.5	46.7	54.9
	3	151.8	75.4	33.4	48.1	56.4
7	1	119.0	72.0	26.0	36.6	48.0
	2	124.7	65.2	27.4	40.0	46.3
	3	126.1	63.8	28.5	41.5	48.0
8	1	98.7	63.0	22.8	32.0	42.0
	2	105.5	56.2	23.6	34.5	39.9
	3	106.7	55.3	24.8	36.1	41.8
9	1	82.7	56.0	20.3	28.4	37.4
	2	90.7	49.3	20.7	30.3	35.0
	3	91.6	48.7	21.9	32.0	37.0
10	1	70.0	50.4	18.2	25.6	33.6
	2	78.8	43.9	18.5	26.9	31.1
	3	79.4	43.6	19.7	28.7	33.2
11	1	59.7	41.8	16.6	23.3	30.6
	2	69.1	39.5	16.6	24.2	28.0
	3	69.4	39.4	17.8	26.0	30.1
12	1	51.3	35.1	15.2	21.3	28.0
	2	61.1	35.9	15.1	22.0	25.5
	3	61.0	36.0	16.3	23.8	27.5
13	1	44.3	29.9	14.0	19.7	25.9
	2	54.4	32.9	13.8	20.2	23.4
	3	54.0	33.1	15.0	21.9	25.3
14	1	38.5	25.8	13.0	18.3	24.0
	2	48.7	30.4	12.8	18.6	21.6
	3	48.0	30.6	13.9	20.3	23.5
15	1	33.6	22.5	12.2	17.1	22.4
	2	43.7	28.2	11.9	17.3	20.0
	3	42.8	28.5	13.0	18.9	21.9
16	1	29.4	19.8	11.4	16.0	21.0
	2	39.5	25.0	11.1	16.1	18.7
	3	38.4	26.7	12.2	17.7	20.5

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 11: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 5 inches
 Panel Width: 42 inches (CF-42)
 Fascia/Liner Profile: Mesa/Mesa Or Flute/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)				
		Panel Stiffness and Strength		Panel Connection Strength ³		
		L/180	Strength	Pattern 1	Pattern 2	Pattern 3
5	1	210.6	113.8	36.5	51.2	67.3
	2	212.5	108.3	38.4	53.9	68.1
	3	213.5	105.6	39.5	55.5	68.8
6	1	170.0	94.8	30.4	42.7	56.0
	2	172.8	88.9	32.6	45.7	55.9
	3	174.1	86.5	33.6	47.2	56.9
7	1	140.5	81.3	26.0	36.6	48.0
	2	144.4	75.0	28.0	39.9	47.2
	3	145.7	73.2	28.7	41.1	48.4
8	1	118.1	71.1	22.8	32.0	42.0
	2	123.0	64.7	24.1	35.2	40.7
	3	124.3	63.3	25.0	36.4	42.1
9	1	100.4	63.2	20.3	28.4	37.4
	2	106.3	56.8	21.2	30.9	35.7
	3	107.5	55.7	22.1	32.2	37.2
10	1	86.2	56.9	18.2	25.6	33.6
	2	93.0	50.5	18.8	27.5	31.8
	3	94.1	49.7	19.8	28.8	33.4
11	1	74.6	51.7	16.6	23.3	30.6
	2	82.2	45.4	16.9	24.7	28.6
	3	83.0	44.9	17.9	26.1	30.2
12	1	65.0	44.9	15.2	21.3	28.0
	2	73.2	41.3	15.4	22.4	25.9
	3	73.7	41.0	16.4	23.9	27.6
13	1	56.9	38.3	14.0	19.7	25.9
	2	65.6	37.8	14.1	20.5	23.8
	3	65.8	37.7	15.1	22.0	25.4
14	1	50.0	33.0	13.0	18.3	24.0
	2	59.1	34.8	13.0	18.9	21.9
	3	59.1	34.8	14.0	20.4	23.6
15	1	44.2	28.8	12.2	17.1	22.4
	2	53.5	32.3	12.0	17.6	20.3
	3	53.3	32.4	13.0	19.0	22.0
16	1	39.2	25.3	11.4	16.0	21.0
	2	48.6	30.1	11.2	16.4	18.9
	3	48.2	30.3	12.2	17.8	20.6

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

Table 12: Maximum Allowable Wind Pressure for Metl-Span CF Composite Foam Wall Panel^{1,2}

Panel Thickness: 6 inches
 Panel Width: 42 inches (CF-42)
 Fascia/Liner Profile: Mesa/Mesa Or Flute/Mesa
 Fascia/Liner Steel Thickness: 26/26

Span (feet)	No of Spans	Allowable Negative and Positive Wind Pressure (psf)				
		Panel Stiffness and Strength		Panel Connection Strength ³		
		L/180	Strength	Pattern 1	Pattern 2	Pattern 3
5	1	225.5	125.4	36.5	51.2	67.3
	2	226.7	120.7	37.9	53.3	68.9
	3	227.4	118.0	38.9	54.6	69.3
6	1	183.6	104.5	30.4	42.7	56.0
	2	185.3	99.3	32.0	45.0	56.7
	3	186.3	96.8	33.0	46.3	57.3
7	1	153.2	89.6	26.0	36.6	48.0
	2	155.6	84.0	27.9	39.1	47.9
	3	156.7	81.8	28.8	40.4	48.8
8	1	130.0	78.4	22.8	32.0	42.0
	2	133.3	72.6	24.5	34.8	41.4
	3	134.4	70.7	25.1	35.9	42.4
9	1	111.8	69.7	20.3	28.4	37.4
	2	115.8	63.7	21.6	31.4	36.4
	3	117.0	62.2	22.2	32.3	37.5
10	1	97.1	62.7	18.2	25.6	33.6
	2	101.9	56.7	19.2	28.0	32.3
	3	103.0	55.5	19.9	29.0	33.6
11	1	84.9	57.0	16.6	23.3	30.6
	2	90.4	51.0	17.3	25.2	29.1
	3	91.5	50.1	18.0	26.3	30.4
12	1	74.8	52.2	15.2	21.3	28.0
	2	80.9	46.3	15.7	22.8	26.4
	3	81.8	45.6	16.5	24.0	27.8
13	1	66.2	46.7	14.0	19.7	25.9
	2	72.9	42.4	14.3	20.9	24.2
	3	73.6	41.9	15.2	22.1	25.6
14	1	58.9	40.3	13.0	18.3	24.0
	2	66.0	39.0	13.2	19.3	22.3
	3	66.6	38.7	14.0	20.5	23.7
15	1	52.5	35.1	12.2	17.1	22.4
	2	60.1	36.2	12.2	17.8	20.6
	3	60.4	36.0	13.1	19.1	22.1
16	1	47.0	30.8	11.4	16.0	21.0
	2	55.0	33.7	11.4	16.6	19.2
	3	55.1	33.6	12.2	17.9	20.6

For SI: 1 foot = 305 mm, 1 psf = 47.9 Pa, 1 inch = 25.4 mm.

¹ The allowable load is the lowest value from the panel strength, stiffness and connection for each condition.

² For unequal multiple spans, the maximum span must be used to determine the allowable pressure from this table.

³ See Figure 4 for details of Metl-Span fastening patterns.

TABLE 13—MAXIMUM ALLOWABLE SPAN (FEET) FOR INTERIOR PARTITION PANELS^{1,2,4}

DESIGN LOAD ³ (psf)	PANEL THICKNESS (inches)					
	2	2.5	3	4	5	6
5	20.8	24.5	27.9	34.1	39.5	42.6

For SI: 1 foot = 305 mm; 1 psf = 47.9 Pa; 1 inch = 25.4 mm.

¹The allowable span is the lowest value from the panel strength, stiffness and connection for single span condition. The panel stiffness is based on the span divided by 120.

²Interior partition panels must be CF42 panels with minimum 26 gage exterior and interior Mesa profiles. Installation must be in accordance with Section 4.2 of this report.

³Transverse load specified in 2018 IBC Section 1607.15, 2015 and 2012 IBC Section 1607.14 and 2009 and 2006 IBC Section 1607.13 for interior partitions. Design load applies to both inward and outward directions.

⁴See Figure 4 or Figure 5 for details on Metl-Span fastening patterns. The fasteners used in Figure 5 must be No. 14 self-drilling or self-tapping screws with a minimum head diameter of 1/2 inch.




FIGURE 1—PANEL PROFILES





FIGURE 2—TYPICAL WALL INSTALLATION



CF PANEL SIDELAP

FIGURE 3—TYPICAL JOINT DETAILS




FIGURE 4—FASTENING PATTERNS FOR CF PANELS




FIGURE 5—ALTERNATE FASTENING PATTERN FOR PARTITION PANELS