



Vertical Panel-Stack Joint Detail

- Notes:
1. Interior perimeter sealants may be omitted for specific applications, subject to the project's design and operational requirements.
  2. Fire protection of support structurals may be required, subject to the project's building code requirements. Fire protection of the structural members is not by Metl-Span.
  3. \*Fastener type is subject to the support structural material and the panel thickness.
  4. To conform to the requirements of the ASTM E 119 fire resistance rating, the filler insulation must have an approved classification marking for surface burning characteristics or fire resistance.

STACK JOINT DETAIL

APPLICATION:  
COOLER/FREEZER

TCS-SJ-01

MSS035.907  
19 AUG 2011